BRANDSERVICE
TRESTAD AB

CERTIFICATE

BRANDSERVICE TRESTAD AB

Intyg över fullgjord BRAND - SERVICE

to certify that fire-extinguishing equipment have been overhauled, repaired, refilled and sealed on date of:
Servicen har blivit utförd den: 2026-10-07

Service och kontroll är utförd å brandredskap tillhörande/
Service and control is carried out on fire-extinguishing equipment belonging to:

KUND: 3850-2 — **M/S TJÖRN SFYM**

SPECIFICERING/SPECIFICATIONS:

1 BATTERY with 1 cylinders for the Fire Extinguishing, system contain a total quantity of 49 kilogrammes of Novec 1230. By controlling these cylinders, I have ascertained that each of the cylinders contains the prescribed pressure of 49 kg.

Antal/pcs.

2	**PULVERSLÄCKARE/DRYPOWDER EXTINGUISHERS**
1	**SKUMSLÄCKARE/FOAM EXTINGUISHERS**
1	**BRANDLARM/FIRE ALARM**

Total: 5 enheter/units

Bifogas/Enclosed; 1. Förteckningar över brandredskap/List of Fire-Extinguisher
2. Utförda arbeten/Work carried out.
Arbetet har utförts enligt gällande bestämmelser/Work is carried out in accordance to the regulations being in force.

Giltighetstid/valid till:
2027-10-06

TROLLHÄTTAN 2026-10-07

Serviceman:
Urban Johansson / Urban Johansson

Brandservice Trestad AB, Sandviksvägen 4, 461 70 TROLLHÄTTAN Tel: 0520-40 91 00
info@brandservicetrestad.com